

## SUBMITTAL SHEET

JOB NAME	ITEM TAG
JOB LOCATION	PART NUMBER
CONTRACTOR	DATE
ENGINEER APPROVAL	DATE

## NO LEAD SCHEDULE 40 RED BRASS NIPPLES

### Plain and Chrome-plated Nipples

Manufactured in compliance with all applicable ASTM and ANSI standards.

Manufactured from Schedule 40 seamless red brass pipe, copper alloy type (UNS) C23000.

Offered in 1/8" through 4" pipe diameters, in lengths close through 12", in addition to smooth chrome-plated versions.

All nipples are threaded at both ends.



**Pictured:**  
Schedule 40 Red  
Brass Nipples

MATERIAL SPECIFICATION		
PART	MATERIAL	SPECIFICATION
1 Body	Red brass	UNS alloy C23000

### Certifications/Listings:

Third-party certified.

NSF/ANSI 61: Drinking water system components - Health effects.

NSF/ANSI 372: Drinking water system components - Lead content

### Standards:

ANSI/ASME B1.20.1: Pipe threads, general purpose, Inch.

ASTM B43-20: Standard specification for seamless red brass pipe, standard sizes.

ASTM B687-99: Standard specification for brass, copper and chromium-plated pipe nipples

ASTM B456: Standard specification for electrodeposited coatings of copper-plus-nickel-plus-chromium and nickel plus chromium (applicable to the chrome-plated nipples)