www.legendvalve.com
800-752-2082

SUBMITTAL SHEET

JOB NAME	ITEM TAG
JOB LOCATION	PART NUMBER
CONTRACTOR	DATE
ENGINEER APPROVAL	DATE

NO LEAD SCHEDULE 40 RED BRASS & CHROME PLATED NIPPLES

NO LEAD PLAIN & CHROME PLATED RED BRASS NIPPLES

Manufactured in compliance with all applicable ASTM and ANSI standards.
Manufactured from Schedule 40 seamless red brass pipe, copper alloy.
Naturally lead-free.
Offered in 1/8" through 4" pipe diameters, in lengths close through 12", in addition to smooth chrome-plated versions.
All nipples are threaded at both ends.



Pictured:
Schedule 40 Red Brass Nipples

MATERIAL SPECIFICATION

	PART	MATERIAL
1	Body	Red Brass

Certifications/Listings: Third-party certified.

NSF/ANSI 61: Drinking water system components - health effects.
NSF/ANSI 372: Drinking water system components - lead content.

Standards:

ANSI/ASME B1.20.1: Pipe threads, general purpose, inch.
ASTM B43-20: Standard specification for seamless red brass pipe, standard sizes.
ASTM B687-99: Standard specification for brass, copper and chromium-plated pipe nipples.
ASTM B456: Standard specification for electrodeposited coatings of copper-plus-nickel-plus-chromium and nickel plus chromium (applicable to chrome-plated nipples).



Pictured:
Chrome-Plated Nipples